

*Kapitula Y. V.*

**The development and research of cable-air line HVDC differential protection algorithm.**

The cable-air line HVDC differential protection algorithm is developed. It is shown that the cable section protection offset in case of fault at the rectifier substation and at the air section and the air section protection offset at the cable line isolation breakdown.

*Key words: differential protection, cable-air line, compensation current.*

*Kapitula Yulia Vladimirovna*, Researcher of Department HVDC Transmission Technology of the Scientific and Technical Center of Unified Power System (STC UPS).

E-mail: kapitula\_y@nipt.ru