

*Vysogorets S. P.*

**Development of diagnosis of manufacturing defects in equipment with polymer insulation in terms of high voltage bushings.**

Specified the impact of applied voltage value on detection of defects in bushings with polymer insulation during infrared diagnostics. It is proposed to regulate the thermal-imaging measurements at the factory tests.

*Key words: bushing, voltage, thermal imaging, trial.*

*Vysogorets Svetlana Petrovna*, PhD. tech., Interregional Distribution Grid Company of North-West (IDGC of the North-West), St. Petersburg.

E-mail: [vsp@mrsksevzap.ru](mailto:vsp@mrsksevzap.ru)