

Improvement of the algorithm for evaluating the correctness of power source participation in the rated primary frequency control.

Esipovich A. H., Kabanov D. A., Prokhorov K. V., Smirnov A. N.

The analysis of one of the monitoring algorithms was performed using real data. A disadvantage of the algorithm has been identified leading to its false triggering. An approach is proposed and implemented to eliminate false triggering.

Key words: monitoring system, algorithm, criterion, power system, frequency control, generating equipment.